



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6102CL0377

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Fratelli Pettinaroli S.p.A. Via Pianelli 38, I-28017 S. Maurizio d' Opaglio (NO)
Distributor <i>Vertreiber</i>	Fratelli Pettinaroli S.p.A. Via Pianelli 38, I-28017 S. Maurizio d' Opaglio (NO)
Product Category <i>Produktart</i>	Stop valves for drinking water: Ball valve (6102)
Product description <i>Produktbezeichnung</i>	ball valve with full bore in angle version for water meters
Model <i>Modell</i>	209; 209/1
Test reports <i>Prüfberichte</i>	Laboratory control test: 298123-1 from 26.03.2025 (DTI) Type testing: 7310366-01 from 10.09.2010 (LGW)
Test basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 13828 (01.12.2003)

Date of Expiry / File No. 14.09.2030 / 25-0530-WNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

11.08.2025 Le A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
209; 209/1	Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 15	abP: PA-IX 16776/I

Type Variation Ausführungsvariante	Explanations Erläuterungen
209	connections: swivel nut 3/4"/female thread 1/2" or 3/4"; with butterfly handle (color: red)
209B	connections: swivel nut 3/4"/female thread 1/2" or 3/4"; with butterfly handle (color: blue)
209V	connections: swivel nut 3/4"/female thread 1/2" or 3/4"; with butterfly handle (color: green)
209/1	connections: swivel nut 3/4"/male thread 1/2" or 3/4"; with butterfly handle (color: red)
209B/1	connections: swivel nut 3/4"/male thread 1/2" or 3/4"; with butterfly handle (color: blue)
209V/1	connections: swivel nut 3/4"/male thread 1/2" or 3/4"; with butterfly handle (color: green)

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Suitability for drinking water hygiene is verified with a "Hygiene confirmation of conformity" in accordance with the currently valid legal basis.

DVGW
CERT